

August 31, 2006

DOC'S SEWER & WATER CO., INC.
DANIEL DOCKENDORF

PO BOX 100
BIG BEND WI 53103

TERRALIFT, INC.
STEVE McBRIAN
104 E MAIN ST.
PO BOX 532
STOCKBRIDGE MA 01262

Re: Description: CHEMICAL OR PHYSICAL RESTORATION FOR POWTS
Manufacturer: TERRALIFT, INC.
Product Name: TERRALIFT
Model Number(s): NONE
Product File No: 20060400

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2011.

This approval is contingent upon compliance with the following stipulation(s):

- Use of this product must comply with the following:
 1. The probe must be inserted no deeper than one foot below the elevation of the infiltrative surface of the distribution/dispersal cell.
 2. The probe must be inserted outside of the distribution/dispersal cell and no closer than one and one-half feet from that edge of the distribution/dispersal cell.
 3. The elevation of the system's infiltrative surface must be above the estimated highest groundwater elevation or bedrock by the distance prescribed in Table Comm 83.44-3, Wis. Adm. Code.
- This product must be utilized in accordance with the manufacturer's printed installation instructions and this product approval. If there is a conflict between the manufacturer's installation instructions and the product approval, the product approval requirements will take precedence.

This approval supersedes the approval issued on INSERT DATE under product file number 20001087.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #20001087.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

DOC'S SEWER & WATER CO., INC.

Page 2

August 31, 2006

Sincerely,

Michael J. Beckwith, CIPE

Plumbing Product Reviewer

phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wisconsin.gov